



Environmental and Laboratory Services

90 ½ West Blackwell St., Dover, New Jersey 07801

(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: September 19, 2016

Client: Roxbury Township BOE
Address: 1 Bryant Drive
Succasunna, NJ 07876

Project: Jefferson Elementary

Sample description: Drinking Water / 1st Draw / DWS3707-1
Sample location: Field Blank
Sampled by: D. Diaz / S. Warner
Sample date: 09/01/16
Sample time: 08:58
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	09/15/16	15:17	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3707-2
Sample location: Main Office/ CFS1
Sampled by: D. Diaz / S. Warner
Sample date: 09/01/16
Sample time: 08:59
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	09/15/16	15:39	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3707-3
Sample location: Nurse / NS1
Sampled by: D. Diaz / S. Warner
Sample date: 09/01/16
Sample time: 09:04
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	7.40 ug/L	15 ug/L	09/15/16	15:50	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3707-4
 Sample location: Kitchen / KPS1
 Sampled by: D. Diaz / S. Warner
 Sample date: 09/01/16
 Sample time: 09:08
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	22.7 ug/L	15 ug/L	09/15/16	15:58	4 ug/L

Sample description: Drinking Water / 1st Draw / DWS3707-5
 Sample location: By Class 24 / WF1
 Sampled by: D. Diaz / S. Warner
 Sample date: 09/01/16
 Sample time: 09:06
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.30 ug/L	15 ug/L	09/15/16	16:04	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3707-6
 Sample location: Faculty Room / FRS1
 Sampled by: D. Diaz / S. Warner
 Sample date: 09/01/16
 Sample time: 09:02
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	5.70 ug/L	15 ug/L	09/15/16	16:09	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3707-7
 Sample location: By Class 10 / WF2
 Sampled by: D. Diaz / S. Warner
 Sample date: 09/01/16
 Sample time: 09:01
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	12.2 ug/L	15 ug/L	09/15/16	16:15	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3707-8
 Sample location: Cafeteria / WF3
 Sampled by: D. Diaz / S. Warner
 Sample date: 09/01/16
 Sample time: 09:07
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	09/15/16	16:20	2 ug/L

ug/L= micrograms per liter


All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Young (For SV)
Susan VanVeen, Lab Manager
NJ Laboratory Certification ID # 14013

September 29, 2016
Date

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Roxbury BOE: Jefferson Elementary School	report to:	Agra Environmental Services
Address: 35 Corn Hollow Road Succasunna, NJ 07876	John Eschmann Roxbury BOE	90½ West Blackwell Street Dover, NJ 07801
County/Municipality:	1 Bryant Dr.	Phone: (973) 989-0010
Phone: John: 973-607-9104	Succasunna, NJ 07876	Fax: (973) 989-0156
Work:	(973) 584-1136	

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project: Jefferson Elementary School Collection PWSID# None for laboratory use only Field Analysis

Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED			
DNS3707												
FIELD BLANK	-1	1-Sep	0858	X		D	1	HNO3	1st Draw Pb < 2 µg/L	9/15/16	1517	BM
MAIN OFFICE/CFS1	-2	1-Sep	0859	X		D	1	HNO3	1st Draw Pb < 2 µg/L		1539	
NURSE/NS1	-3	1-Sep	0904	X		D	1	HNO3	1st Draw Pb 7.40 µg/L		1550	
KITCHEN/KPS1	-4	1-Sep	0908	X		D	1	HNO3	1st Draw Pb 22.7 µg/L		1558	1:2
BY CLASS 24/WF1	-5	1-Sep	0906	X		D	1	HNO3	1st Draw Pb 3.30 µg/L		1604	
FACULTY ROOM/FRS1	-6	1-Sep	0902	X		D	1	HNO3	1st Draw Pb 5.70 µg/L		1609	
BY CLASS 10/WF2	-7	1-Sep	0901	X		D	1	HNO3	1st Draw Pb 12.2 µg/L		1615	
CAFETERIA/WF3	-8	1-Sep	0907	X		D	1	HNO3	1st Draw Pb 6.2 µg/L		1620	

Sampled By (name/company): D. Diaz/S. Warner	State Forms Needed (circle one): Yes or No	indicate laboratory location where analysis requested was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013	
	NJDEP Laboratory Certification (Marlboro, NJ) #13033	

Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:
-------------------------------------	----------	------------	-----------------	---

Sample Custody Exchanges (Please use full legal signature)						Scanned _____	
Relinquished By: <i>Daniela Diaz</i>	Date: 9/1/16	Time: 1120	Received By: <i>Stephanie</i>	Date: 9/1/16	Time: 1120	year 2016	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
						Date Faxed _____	
						Invoice Number _____	
						Is sample known to be hazardous? (circle one) Yes or No	