



Environmental and Laboratory Services
 90 ½ West Blackwell St., Dover, New Jersey 07801
 (973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: June 12, 2017
 Address: Roxbury Township BOE
 1 Bryant Drive
 Succasunna, NJ 07876

Project: Roxbury High School

Sample description: Drinking Water / 1st Draw / DWS5460-1
 Sample location: Field Blank
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:02
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/25/17	22:55	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-2
 Sample location: RHS-FB-Boys Locker Rm
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:03
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/25/17	23:02	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-3
 Sample location: RHS-FC-HW-by weight Room 01
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:05
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/25/17	23:08	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-4
 Sample location: RHS-FC-HW by Weight Room 02
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:06
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/25/17	23:21	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-5
 Sample location: RHS-SO-Athletic Training Rm
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:08
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/25/17	23:27	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-6
 Sample location: RHS-IM Athletic Training Rm
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:09
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/25/17	23:34	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-7
 Sample location: RHS-FB-HW-Entrance Gym Boys
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:11
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/25/17	23:40	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-8
 Sample location: RHS-FB-HW-Entrance Gym Girls
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:12
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/25/17	23:46	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-9
 Sample location: RHS-FB-Girls Locker Room
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:14
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.09 µg/L	15 µg/L	05/25/17	23:53	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-10
 Sample location: RHS-BF-HW by D131
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:15
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/25/17	23:59	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-11
 Sample location: RHS-BF-HW by D138
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:17
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	00:06	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-12
 Sample location: RHS-MO-Nurse
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:19
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.16 µg/L	15 µg/L	05/26/17	00:13	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-13
 Sample location: RHS-SO-C122-01
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:22
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	00:19	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-14
 Sample location: RHS-SO-C122-02
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:24
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	00:38	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-15
 Sample location: RHS-FB-HW-F154S-01
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:26
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.53 µg/L	15 µg/L	05/26/17	00:44	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-16
 Sample location: RHS-FB-HW by F154S-02
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:27
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	00:56	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-17
 Sample location: RHS-FC-HW by E144
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:28
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	01:20	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-18
 Sample location: RHS-SO-Main Office
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:29
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	01:26	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-19
 Sample location: RHS- HE-B113-01
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:32
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	01:31	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-20
 Sample location: RHS-HE-B113-02
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:33
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	01:37	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-21
 Sample location: RHS-HE_B113-03
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:34
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	01:43	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-22
 Sample location: RHS-HE-B113-04
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:35
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	01:49	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-23
 Sample location: RHS-HE-B113-05
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:36
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.36 µg/L	15 µg/L	05/26/17	02:01	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-24
 Sample location: RHS-HE-B113-06
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:37
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	02:08	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-25
 Sample location: RHS-SO-B117
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:35
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	02:14	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-26
 Sample location: RHS-FB-HW-by B117
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:36
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	02:20	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-27
 Sample location: RHS-SO-A104
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:38
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.60 µg/L	15 µg/L	05/26/17	02:26	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-28
 Sample location: RHS-HE-A106-01
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:40
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	02:32	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-29
 Sample location: RHS-HE-A106-02
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:40
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	02:38	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-30
 Sample location: RHS-HE-A106-03
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:40
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	02:45	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-31
 Sample location: RHS-HE-A106-04
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:41
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	02:51	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-32
 Sample location: RHS-HE-A106-05
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:41
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	02:57	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-33
 Sample location: RHS-HE-A106-06
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:42
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	03:15	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-34
 Sample location: RHS-SO-G163
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:45
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.85 µg/L	15 µg/L	05/26/17	03:21	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-35
 Sample location: RHS-FB-HW by A107
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:47
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.43 µg/L	15 µg/L	05/26/17	03:33	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-36
 Sample location: RHS-KO-Kitchen-01
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:49
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	03:57	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-37
 Sample location: RHS-KO-Kitchen-02
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:50
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.41 µg/L	15 µg/L	05/26/17	04:03	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-38
 Sample location: RHS-IM-Kitchen
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:51
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	04:08	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-39
 Sample location: RHS-KO-Kitchen-03
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:52
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.13 µg/L	15 µg/L	05/26/17	04:14	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-40
 Sample location: RHS-KO-Kitchen-04
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:53

B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.61 µg/L	15 µg/L	05/26/17	04:21	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-41
 Sample location: RHS-FB-Caferteria-01
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:54
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	04:27	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-42
 Sample location: RHS-FB-Caferteria-02
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:55
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	04:39	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-43
 Sample location: RHS-FB-HW-by H170
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 06:57
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	04:46	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-44
 Sample location: RHS-FB-HW-by O233
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 07:01
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	7.60 µg/L	15 µg/L	05/26/17	04:52	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-45
 Sample location: RHS-FB-HW by O237
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 07:02
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	04:58	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-46
 Sample location: RHS-FB-HW by Q252S-01
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 07:03
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	05:03	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-47
 Sample location: RHS-FB-HW by Q252S-02
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 07:07
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	05:09	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-48
 Sample location: RHS-TL-Teacher's Lounge
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 07:08
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	05:15	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-49
 Sample location: RHS-FB-HW by M218
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 07:09
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	05:21	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-50
 Sample location: RHS-BF-HW by L201
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 07:11
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/26/17	05:27	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-51
 Sample location: RHS-FB-HW by L209
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 07:13
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.15 µg/L	15 µg/L	05/26/17	18:34	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-52
 Sample location: RHS-CS-Concession Stand-01
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 07:29
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2,276 µg/L	15 µg/L	05/30/17	17:37	1,000	2,000 µg/L

Sample description: Drinking Water / 1st Draw / DWS5460-53
 Sample location: RHS-CS-Concession Stand-02
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 07:30
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.78 µg/L	15 µg/L	05/26/17	18:53	1	2.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

05/13/17
 Date

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Asc./HCl Vials pH: _____
 # HCl Vials pH: _____
 # Na₂S₂O₃ Cl₂: _____
 # HNO₃ (50%) pH: 5.3
 # H₂SO₄ pH: _____
 # NaOH pH: _____
 # unpreserved _____
 # other _____

Agra Environmental Services
 90 1/2 West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Customer Name: Roxbury High School
 Address: 1 Bryant Dr
 Succasunna NJ 07876
 County/Municipality:
 Phone: (973)-584-1200
 Work: John 973-607-9104

report to: _____
 Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake

Project: _____ for laboratory use only

Field ID	Lab ID:	Collection		PWSID# NJ			ANALYSIS REQUESTED	Field Analysis	
		Date	Time	Grab	Comp	Matrix			# of Bottles
Field Blank	DW 55160	5/13/17	06:02	X		DW	1	NHO3	1st Draw PB 2.00 ug/L 5/15/17 2255 BM
RHS-FB-Boys Locker Rm			06:03	X		DW	1	NHO3	1st Draw PB 2.00 2302
RHS-FC-HW by weight Room 01-3			06:05	X		DW	1	NHO3	1st Draw PB 2.00 2308
RHS-FC-HW by weight Room 02-4			06:06	X		DW	1	NHO3	1st Draw PB 2.00 2321
RHS-SO - Athletic Training Rm 5			06:08	X		DW	1	NHO3	1st Draw PB 2.00 2327
RHS-IM-Athletic Training Rm 6			06:09	X		DW	1	NHO3	1st Draw PB 2.00 2334
RHS-FB-HW Entrance Gym Boys 3			06:11	X		DW	1	NHO3	1st Draw PB 2.00 2340
RHS-FB-HW Entrance Gym Girls 4			06:12	X		DW	1	NHO3	1st Draw PB 2.00 2346
RHS-FB - Girls Locker Room 19			06:14	X		DW	1	NHO3	1st Draw PB 4.00 2353
RHS-BF-HW by D131 20			06:15	X		DW	1	NHO3	1st Draw PB 2.00 2359

State Forms Needed (circle one): Yes or No
 NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033
 Reporting Requirements (Check Box):
 Standard _____
 NJ Reduced _____
 Other (Specify) _____
 Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Received By:	Date:	Time:	Date:	Time:	Scanned
<i>[Signature]</i>	<i>[Signature]</i>	5/13/17	12:38	5/13/17	12:45	
Relinquished By:	Received By:	Date:	Time:	Date:	Time:	
Relinquished By:	Received By:	Date:	Time:	Date:	Time:	
Relinquished By:	Received By:	Date:	Time:	Date:	Time:	

Date Faxed: _____
 Invoice Number: _____
 Is sample known to be hazardous? (circle one)
 Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST



Customer Name: Roxbury High School
 Address: 1 Bryant Dr
 Succasunna NJ 07876
 County/Municipality:
 Phone: (973)-584-1200
 Work:
 report to:
 Agra Environmental Services
 90 1/2 West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake		Page <u>2</u> of <u>2</u>					
Project:	PWSID# NJ	Field Analysis					
Lab ID:	Collection						
Field ID	Date	Time					
	Grab	Comp					
	Matrix	# of Bottles					
	Preservative	ANALYSIS REQUESTED					
DWS5160	5/13/17	06:17	X	DW	1	NHO3	1st Draw PB 2.00 wall 5/26/17 0006 BM
		06:19	X	DW	1	NHO3	1st Draw PB 2.16 0013
		06:22	X	DW	1	NHO3	1st Draw PB 2.00 0019
		06:24	X	DW	1	NHO3	1st Draw PB 2.00 0038
		06:26	X	DW	1	NHO3	1st Draw PB 2.53 0044
		06:27	X	DW	1	NHO3	1st Draw PB 2.00 0056
		06:28	X	DW	1	NHO3	1st Draw PB 2.00 0120
		06:29	X	DW	1	NHO3	1st Draw PB 2.00 0126
		06:32	X	DW	1	NHO3	1st Draw PB 2.00 0131
		06:33	X	DW	1	NHO3	1st Draw PB 2.00 0137

State Forms Needed (circle one): Yes or No
 NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):
 Standard NJ Reduced Other (Specify)

Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)

Relinquished By: [Signature] Date: 5/13/17 Time: 12:38

Relinquished By: _____ Date: _____ Time: _____

Relinquished By: _____ Date: _____ Time: _____

Relinquished By: _____ Date: _____ Time: _____

Scanned _____

Date Faxed: _____ Invoice Number: _____

Is sample known to be hazardous? (circle one)
 Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST



Agra Environmental Services
 90½ West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Customer Name: Roxbury High School
 Address: 1 Bryant Dr
 Succasunna, NJ 07876
 Phone: (973)-584-1200
 Work:

report to:

Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake
 Project: _____ for laboratory use only

Field ID	Lab ID:	Collection		PWSID# NJ			ANALYSIS REQUESTED	Field Analysis
		Date	Time	Grab	Comp	Matrix		

RHS-HE-B113-03	0055160	5/13/17	06:34	X	DW	1	NHO3	1st Draw PB 2.00 ug/L 5/26/17	0143	GM
RHS-HE-B113-04			06:35	X	DW	1	NHO3	1st Draw PB 2.00	0144	
RHS-HE-B113-05			06:36	X	DW	1	NHO3	1st Draw PB 3.36	0201	
RHS-HE-B113-06			06:37	X	DW	1	NHO3	1st Draw PB 2.00	0208	
RHS-SO-B117			06:35	X	DW	1	NHO3	1st Draw PB 2.00	0214	
RHS-FB-HW by B117			06:36	X	DW	1	NHO3	1st Draw PB 2.00	0220	
RHS-SO-A104			06:38	X	DW	1	NHO3	1st Draw PB 2.60	0226	
RHS-HE-A106-01			06:40	X	DW	1	NHO3	1st Draw PB 2.00	0232	
RHS-HE-A106-02			06:40	X	DW	1	NHO3	1st Draw PB 2.00	0238	
RHS-HE-A106-03			06:46	X	DW	1	NHO3	1st Draw PB 2.00	0245	

State Forms Needed (circle one): Yes or No
 indicate laboratory location where analysis requested was performed
 NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)
			Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)		Scanned	
Relinquished By:	Received By:	Date:	Time:
<i>[Signature]</i>	<i>[Signature]</i>	5/13/17	10:38
Relinquished By:	Received By:	Date:	Time:
Relinquished By:	Received By:	Date:	Time:
Relinquished By:	Received By:	Date:	Time:
Relinquished By:	Received By:	Date:	Time:

Date Faxed: _____ Invoice Number: _____
 Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST



Customer Name: Roxbury High School
 Address: 1 Bryant Dr
 Succasunna NJ 07876
 County/Municipality:
 Phone: (973)-584-1200
 Work:
 report to:
 Agra Environmental Services
 90 1/2 West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Matrix Abbreviations:	D - Drinking Water	G - Groundwater	W - Wastewater	S - Soil	SL - Sludge	P - Pool	L - Lake	Page <u>4</u> of <u>6</u>		
Project:	PWSID# NJ							Field Analysis		
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	for laboratory use only
RHS-HE-A106-04	DW55460	5/13/17	08:41	X	DW	DW	1	NHO3	1st Draw PB 2.00 ug/L 5/26/17 0251	BM
RHS-HE-A106-05			06:41	X	DW	DW	1	NHO3	1st Draw PB 2.00	0257
RHS-HE-A106-06			06:42	X	DW	DW	1	NHO3	1st Draw PB 2.00	0315
RHS-SO-G163			06:45	X	DW	DW	1	NHO3	1st Draw PB 6.85	0321
RHS-FB-HW by A107			06:45	X	DW	DW	1	NHO3	1st Draw PB 4.43	0333
RHS-KO-Kitchen-01			06:49	X	DW	DW	1	NHO3	1st Draw PB 2.00	0357
RHS-KO-Kitchen-02			06:50	X	DW	DW	1	NHO3	1st Draw PB 2.41	0403
RHS-IM-Kitchen			06:51	X	DW	DW	1	NHO3	1st Draw PB 2.00	0408
RHS-KO-Kitchen-03			06:52	X	DW	DW	1	NHO3	1st Draw PB 5.13	0414
RHS-KO-Kitchen-04			06:53	X	DW	DW	1	NHO3	1st Draw PB 5.61	0421
State Forms Needed (circle one): Yes or No NJDEP Laboratory Certification (Dover, NJ) #14013 NJDEP Laboratory Certification (Marlboro, NJ) #13033 Cooler Temperature/Upon Receipt at lab: N/A										

Reporting Requirements (Check Box):
 Scanned _____
Sample Custody Exchanges (Please use full legal signature)
 Relinquished By: [Signature] Received By: _____
 Date: 5/13/17 Time: 12:38
 Relinquished By: _____ Received By: _____
 Date: _____ Time: _____
 Relinquished By: _____ Received By: _____
 Date: _____ Time: _____
 Relinquished By: _____ Received By: _____
 Date: _____ Time: _____
 Is sample known to be hazardous? (circle one)
 Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Roxbury High School Address: 1 Bryant Dr Succasunna NJ 07876 County/Municipality: Phone: (973)-584-1200 Work:	report to: Agra Environmental Services 90 1/2 West Blackwell Street Dover, NJ 07801 Phone: (973) 989-0010 Fax: (973) 989-0156
---	--



Project:	Matrix Abbreviations:		G-Groundwater	W-Wastewater	S-Soil	SL-Sludge	P-Pool	L-Lake	Page <u>1</u> of <u>1</u>	Field Analysis
	D - Drinking Water	W - Wastewater								
Lab ID:	Date	Time	Collection	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	
RHS-FB-Cafeteria-01	5/13/17	06:54	X	X	DW	DW	1	NHO3	1st Draw PB 2.00 ug/L	5/26/17 0427 BM
RHS-FB-Cafeteria-02		06:55	X	X	DW	DW	1	NHO3	1st Draw PB 2.00	0439
RHS-FB-HW by H170		06:57	X	X	DW	DW	1	NHO3	1st Draw PB 2.00	0446
RHS-FB-HW by O233		07:01	X	X	DW	DW	1	NHO3	1st Draw PB 7.60	0452
RHS-FB-HW by O237		07:02	X	X	DW	DW	1	NHO3	1st Draw PB 2.00	0458
RHS-FB-HW by Q252S-01		07:03	X	X	DW	DW	1	NHO3	1st Draw PB 2.00	0503
RHS-FB-HW by Q252S-02		07:07	X	X	DW	DW	1	NHO3	1st Draw PB 2.00	0509
RHS-TL-Teachers Lounge		07:08	X	X	DW	DW	1	NHO3	1st Draw PB 2.00	0515
RHS-FB-HW by M218		07:09	X	X	DW	DW	1	NHO3	1st Draw PB 2.00	0521
RHS-BF-HW by L201		07:11	X	X	DW	DW	1	NHO3	1st Draw PB 2.00	0527

State Forms Needed (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)

Relinquished By: <u>[Signature]</u>	Received By: <u>[Signature]</u>	Date: <u>5/13/17</u>	Time: <u>10:58</u>
Relinquished By:	Received By:	Date:	Time:
Relinquished By:	Received By:	Date:	Time:
Relinquished By:	Received By:	Date:	Time:

Scanned _____

Date Faxed _____

Invoice Number _____

Is sample known to be hazardous? (circle one)
 Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Roxbury High School	report to:	Agra Environmental Services 90½ West Blackwell Street Dover, NJ 07801 Phone: (973) 989-0010 Fax: (973) 989-0156
Address: 1 Bryant Dr		
County/Municipality: Succasunna NJ07876		
Phone: (973)-584-1200		
Work:		

Matrix Abbreviations:	D - Drinking Water	G - Groundwater	W - Wastewater	S - Soil	SL - Sludge	P - Pool	L - Lake	Page <u>6</u> of <u>6</u>
Project:								Field Analysis
Lab ID:	Collection							
	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED
RHS-FB-HW by L209	5/13/17	07:13	X	DW	DW	1	NHO3	1st Draw PB 4.15 ug/L 5/26/17 1834 gm
RHS-CS-Consession Stand-01-5A	1	07:29	X	DW	DW	1	NHO3	1st Draw PB 2.276 ug/L 5/30/17 1739 gm
RHS-CS-Consession Stand-02-4A	↓	07:30	X	DW	DW	1	NHO3	1st Draw PB 5.78 ug/L 5/26/17 1653 gm
			X	DW	DW	1	NHO3	1st Draw PB
			X	DW	DW	1	NHO3	1st Draw PB
			X	DW	DW	1	NHO3	1st Draw PB
			X	DW	DW	1	NHO3	1st Draw PB
			X	DW	DW	1	NHO3	1st Draw PB
			X	DW	DW	1	NHO3	1st Draw PB
			X	DW	DW	1	NHO3	1st Draw PB
			X	DW	DW	1	NHO3	1st Draw PB

Sampled By (name/company): SB/s.c. / agra

State Forms Needed (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):

	Standard	NJ Reduced	Other (Specify)
			N/A

Cooler Temperature Upon Receipt at lab: _____

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date: 5/13/17	Time: 10:38	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:

Scanned: _____

Date Faxed: _____

Invoice Number: _____

Is sample known to be hazardous? (circle one)
 Yes or No