



Environmental and Laboratory Services
90 ½ West Blackwell St., Dover, New Jersey 07801
(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: May 30, 2017
Address: Roxbury Township BOE
1 Bryant Drive
Succasunna, NJ 07876

Project: Jefferson Elementary School

Sample description: Drinking Water / 1st Draw / DWS5457-1
Sample location: Field Blank
Sampled by: S. Lamond / S. Berta
Sample date: 05/13/17
Time: 09:10
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/24/17	17:33	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-2
Sample location: JES-KO-Kitchen
Sampled by: S. Lamond / S. Berta
Sample date: 05/13/17
Time: 09:11
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.41 µg/L	15 µg/L	05/24/17	17:38	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-3
Sample location: JES-FC-Cafeteria
Sampled by: S. Lamond / S. Berta
Sample date: 05/13/17
Time: 09:12
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/24/17	17:44	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-4
Sample location: JES-FB-HW Gym & Rm 35
Sampled by: S. Lamond / S. Berta
Sample date: 05/13/17
Time: 09:13
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/24/17	17:49	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-5
 Sample location: JES-FB-24
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:14
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	14.9 µg/L	15 µg/L	05/24/17	17:55	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-6
 Sample location: JES-FB-22
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:15
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	17.9 µg/L	15 µg/L	05/24/17	18:00	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-7
 Sample location: JES-FB-20
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:16
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	8:35 µg/L	15 µg/L	05/24/17	18:17	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-8
 Sample location: JES-FB-19
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:17
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	12.6 µg/L	15 µg/L	05/24/17	18:28	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-9
 Sample location: JES-FB-17
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:18
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.20 µg/L	15 µg/L	05/24/17	18:50	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-10
 Sample location: JES-FB-18
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:20
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	8.77 µg/L	15 µg/L	05/24/17	18:55	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-11
 Sample location: JES-FB-16
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:20
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.91 µg/L	15 µg/L	05/24/17	19:01	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-12
 Sample location: JES-FB-15
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:21
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.76 µg/L	15 µg/L	05/24/17	19:06	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-13
 Sample location: JES-FB-13
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:22
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.36 µg/L	15 µg/L	05/24/17	19:12	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-14
 Sample location: JES-MO-Nurse
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:24
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.90 µg/L	15 µg/L	05/24/17	19:17	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-15
 Sample location: JES-TL-Teachers Lounge
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:25
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.50 µg/L	15 µg/L	05/24/17	19:23	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-16
 Sample location: JES-FB-14
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:26
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	14.4 µg/L	15 µg/L	05/24/17	19:34	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-17
 Sample location: JES-SO-48B
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:27
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.10 µg/L	15 µg/L	05/24/17	19:40	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-18
 Sample location: JES-FB-11
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:29
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	9.92 µg/L	15 µg/L	05/24/17	19:45	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-19
 Sample location: JES-FB-12
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:30
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.44 µg/L	15 µg/L	05/24/17	19:51	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-20
 Sample location: JES-FB-09
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:32
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	8.63 µg/L	15 µg/L	05/24/17	19:56	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-21
 Sample location: JES-FB-10
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:33
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.51 µg/L	15 µg/L	05/24/17	20:02	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-22
 Sample location: JES-FB-07
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:35
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	19.9 µg/L	15 µg/L	05/24/17	20:13	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-23
 Sample location: JES-FB-HW by Rm 07
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:36
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	11.1 µg/L	15 µg/L	05/24/17	20:19	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-24
 Sample location: JES-FB-08
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:37
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.65 µg/L	15 µg/L	05/24/17	20:25	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-25
 Sample location: JES-FB-06
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:37
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	7.91 µg/L	15 µg/L	05/24/17	20:31	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-26
 Sample location: JES-FB-05
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:39
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	11.3 µg/L	15 µg/L	05/24/17	20:48	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-27
 Sample location: JES-FB-03
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:40
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	11.1 µg/L	15 µg/L	05/24/17	21:00	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-28
 Sample location: JES-FB-04
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:40
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.66 µg/L	15 µg/L	05/24/17	21:22	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-29
 Sample location: JES-FB-02
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:42
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	9.22 µg/L	15 µg/L	05/24/17	21:28	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5457-30
 Sample location: JES-FB-01
 Sampled by: S. Lamond / S. Berta
 Sample date: 05/13/17
 Time: 09:43
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	11.6 µg/L	15 µg/L	05/24/17	21:33	1	2.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Suzette Veen (For SV)
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

June 6, 2017
 Date

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Asc./HCl Vials pH: _____
 # HCl Vials pH: _____
 # Na₂S₂O₃ Cl₂: _____
 # HNO₃ (50%) pH: 2
 # H₂SO₄ pH: _____
 # NaOH pH: _____
 # unpreserved _____
 # other _____
 # _____

Agra Environmental Services
 90½ West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Customer Name: Jefferson Elementary School
 Address: 35 Corn Hollow Rd
 Succasunna NJ 07876
 County/Municipality:
 Phone: (973)-584-8955
 Work:

report to: _____
 Matrix: _____
 Comp: _____
 Grab: _____

Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake

Project: _____ for laboratory use only

Field ID	Lab ID:	Date	Time	Collection	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED
Field Blank	DW55457	5/13/17	09:10	X	DW	1	NHO3	1	NHO3	1st Draw PB 2.00 well SM117 1733 BM
JES-KO-Kitchen			09:11	X	DW	1	NHO3	1	NHO3	1st Draw PB 6.44 1738
JES-FC-Cafeteria			09:12	X	DW	1	NHO3	1	NHO3	1st Draw PB 2.00 1744
JES-FB-HW Gym & Rm 35			09:13	X	DW	1	NHO3	1	NHO3	1st Draw PB 2.00 1749
JES-FB-24			09:14	X	DW	1	NHO3	1	NHO3	1st Draw PB 14.9 1755
JES-FB-22			09:15	X	DW	1	NHO3	1	NHO3	1st Draw PB 17.4 1800
JES-FB-20			09:16	X	DW	1	NHO3	1	NHO3	1st Draw PB 8.35 1817
JES-FB-19			09:17	X	DW	1	NHO3	1	NHO3	1st Draw PB 12.6 1828
JES-FB-17			09:18	X	DW	1	NHO3	1	NHO3	1st Draw PB 6.30 1850
JES-FB-18			09:20	X	DW	1	NHO3	1	NHO3	1st Draw PB 8.77 1855



Sampled By (name/company): SB/SL/Agra

State Forms Needed (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):
 Standard NJ Reduced Other (Specify) _____
 Cooler Temperature Upon Receipt at lab: NA

Indicate laboratory location where analysis requested was performed

Sample Custody Exchanges (Please use full legal signature)		Scanned	
Relinquished By: 	Date: 5/13/17 Time: 12:45	Date: 5/13/17 Time: 12:45	Date: _____ Time: _____
Relinquished By: 	Date: _____ Time: _____	Date: _____ Time: _____	Date: _____ Time: _____
Relinquished By: _____	Date: _____ Time: _____	Date: _____ Time: _____	Date: _____ Time: _____
Relinquished By: _____	Date: _____ Time: _____	Date: _____ Time: _____	Date: _____ Time: _____

Date Faxed: _____ Invoice Number: _____
 Is sample known to be hazardous? (circle one)
 Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Jefferson Elementary School Address: 35 Corn Hollow Rd Succasunna NJ 07876 Phone: (973)-584-8955 Work:	report to: Agra Environmental Services 90½ West Blackwell Street Dover, NJ 07801 Phone: (973) 989-0010 Fax: (973) 989-0156
-----------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------



Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake		Page 2 of 5
Project:		Field Analysis
Field ID	Lab ID: <i>DW55457</i>	ANALYSIS REQUESTED
JES-FB-16	<i>5/13/17</i>	1st Draw PB <i>4.41 u/L</i> 5/24/17 1901 BM
JES-FB-15	<i>15</i>	1st Draw PB <i>5.76</i> 1906
JES-FB-13	<i>13</i>	1st Draw PB <i>4.36</i> 1912
JES-MO-Nurse	<i>14</i>	1st Draw PB <i>5.90</i> 1917
JES-TL-Teachers Lounge	<i>15</i>	1st Draw PB <i>2.50</i> 1923
JES-FB-14	<i>14</i>	1st Draw PB <i>14.4</i> 1934
JES-SO-48B	<i>17</i>	1st Draw PB <i>3.10</i> 1940
JES-FB-11	<i>11</i>	1st Draw PB <i>4.97</i> 1945
JES-FB-12	<i>12</i>	1st Draw PB <i>6.44</i> 1951
JES-FB-09	<i>09</i>	1st Draw PB <i>8.63</i> 1956

State Forms Needed (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis requested was performed

Reporting Requirements (Check Box):

Standard	NJ Reduced	Other (Specify)
		NA

Cooler Temperature Upon Receipt at lab: NA

Sample Custody Exchanges (Please use full legal signature)			
Relinquished By:	Date: <i>5/13/17</i>	Time: <i>12:40</i>	Received By:
Relinquished By:	Date:	Time:	Received By:
Relinquished By:	Date:	Time:	Received By:
Relinquished By:	Date:	Time:	Received By:

Scanned _____

Date Faxed _____

Invoice Number _____

Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Jefferson Elementary School Address: 35 Corn Hollow Rd Succasunna NJ 07876 County/Municipality: Phone: (973)-584-8955 Work:	report to: Agra Environmental Services 90 1/2 West Blackwell Street Dover, NJ 07801 Phone: (973) 989-0010 Fax: (973) 989-0156
-----------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------



Matrix Abbreviations:	D - Drinking Water	G - Groundwater	W - Wastewater	S - Soil	SL - Sludge	P - Pool	L - Lake	Page <u>3</u> of <u>3</u>
Project:	for laboratory use only							Field Analysis
Lab ID:	Collection	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative
JES-FB-10		5/13/17	09:33	X		DW	1	NHO3
JES-FB-07			09:35	X		DW	1	NHO3
JES-FB-HW by Rim 07			09:36	X		DW	1	NHO3
JES-FB-08			09:37	X		DW	1	NHO3
JES-FB-06			09:37	X		DW	1	NHO3
JES-FB-05			09:39	X		DW	1	NHO3
JES-FB-03			09:40	X		DW	1	NHO3
JES-FB-04			09:40	X		DW	1	NHO3
JES-FB-02			09:42	X		DW	1	NHO3
JES-FB-01			09:43	X		DW	1	NHO3

ANALYSIS REQUESTED
 1st Draw PB 3.51 ug/L 5/24/17 2007 BM
 1st Draw PB 14.9 2013
 1st Draw PB 11.1 2019
 1st Draw PB 5.65 2025
 1st Draw PB 7.91 2031
 1st Draw PB 11.3 2048
 1st Draw PB 11.1 2100
 1st Draw PB 5.16 2122
 1st Draw PB 0.22 2128
 1st Draw PB 11.6 2133

State Forms Needed (circle one): Yes or No
 NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):
 NJ Reduced
 Other (Specify)

Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)			
Relinquished By:	Received By:	Date:	Time:
<i>[Signature]</i>	<i>[Signature]</i>	5/13/17	09:40
Relinquished By:	Received By:	Date:	Time:
Relinquished By:	Received By:	Date:	Time:
Relinquished By:	Received By:	Date:	Time:
Relinquished By:	Received By:	Date:	Time:

Scanned _____

Date Faxed _____
 Invoice Number _____
 Is sample known to be hazardous? (circle one)
 Yes or No

Attachment C - Drinking Water Outlet Inventory

Building Name: Jefferson School

Address:

Grade Levels:

Individual School Project Officer Name:

Signature:

Completion Date:

Original Yr of Construction: Additional Yrs of Construction:

# ¹	Type	Location Description	Location Code School/Type/Level/Wing/Rm/Fixture#	Operational ² Y/N	Signs of Corrosion/Leaking ³ Y/N	Filter ⁴ Y/N	Brass Fittings, Faucets or Valves Y/N/UKN	Screen/Aerator Used Y/N	Motion Activated Y/N	Chiller Y/N	Water Cooler Make ⁵	Water Cooler Model ⁶	Frequently Used Y/N	Comment
1	Kitchen Outlet	Kitchen Sink	JES-KO-Kitchen	Y	N	N	Y	Y	N	N	n/a	n/a	Y	
2	Fountain Chiller	Cafeteria Chiller	JES-FC-Cafeteria	Y	N	N	Y	Y	N	N	Elkay	Unknown	Y	
3	Fountain Bubbler	Hallway by Gym & Rm 35 Bubbler	JES-FB-HW Gym & Rm 35	Y	N	N	Y	Y	N	N	Central	Unknown	Y	
4	Bubbler with Sink	Room 24 Bubbler	JES-FB-24	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
5	Bubbler with Sink	Room 22 Bubbler	JES-FB-22	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
6	Bubbler with Sink	Room 20 Bubbler	JES-FB-20	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
7	Bubbler with Sink	Room 19 Bubbler	JES-FB-19	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
8	Bubbler with Sink	Room 17 Bubbler	JES-FB-17	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
9	Bubbler with Sink	Room 18 Bubbler	JES-FB-18	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
10	Bubbler with Sink	Room 16 Bubbler	JES-FB-16	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
11	Bubbler with Sink	Room 15 Bubbler	JES-FB-15	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
12	Bubbler with Sink	Room 13 Bubbler	JES-FB-13	Y	N	N	Y	Y	N	N	Center	Unknown	Y	

#1	Type	Location Description	Location Code School/Type/Level/Wing/Rm/Fixture#	Operational ² Y/N	Signs of Corrosion/Leaking ³ Y/N	Filter ⁴ Y/N	Brass Fittings, Faucets or Valves Y/N/UKIN	Screen/Aerator Used Y/N	Motion Activated Y/N	Chiller Y/N	Water Cooler Make ⁵	Water Cooler Model ⁵	Frequently Used Y/N	Comment
13	Medical Outlet	Nurse Sink	JES-MO-Nurse	Y	N	N	Y	Y	N	N	N/A	N/A	Y	
14	Teacher Lounge Sink	Teacher Lounge Sink	JES-TL-Teachers Lounge	Y	N	N	N	Y	N	N	MOEN	Unknown	Y	
15	Bubbler with Sink	Room 14 Bubbler	JES-FB-14	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
16	Sink Outlet	Room 48B Main Office Conference Rm Sink	JES-SO-48B	Y	N	N	Y	Y	N	N	CHICAGO	Unknown	Y	
17	Bubbler with Sink	Room 11 Bubbler	JES-FB-11	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
18	Bubbler with Sink	Room 12 Bubbler	JES-FB-12	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
19	Bubbler with Sink	Room 09 Bubbler	JES-FB-09	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
20	Bubbler with Sink	Room 10 Bubbler	JES-FB-10	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
21	Bubbler with Sink	Room 07 Bubbler	JES-FB-07	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
22	Fountain Bubbler	Hallway by Room 07	JES-FB-HW by Rm 07	Y	N	N	Y	Y	N	N	Porcelain	Unknown	Y	
23	Bubbler with Sink	Room 08 Bubbler	JES-FB-08	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
24	Bubbler with Sink	Room 06 Bubbler	JES-FB-06	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
25	Bubbler with Sink	Room 05 Bubbler	JES-FB-05	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
26	Bubbler with Sink	Room 03 Bubbler	JES-FB-03	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
27	Bubbler with Sink	Room 04 Bubbler	JES-FB-04	Y	N	N	Y	Y	N	N	Center	Unknown	Y	
28	Bubbler with Sink	Room 02 Bubbler	JES-FB-02	Y	N	N	Y	Y	N	N	Center	Unknown	Y	

29) Bubbler with Sink	Room 01 Bubbler	JES-FB-01	Y	N	N	Y	Y	N	N	N	Center	Unknown	Y	
<p>1 Number outlets starting at the closet drinking water outlet to the Point of Entry (POE)</p> <p>2 Document if permanently or temporarily out of service on the Attachment B Plumbing Profile</p> <p>3 Signs of Corrosion detected, such as but not limited to (frequent leaks, rust colored water, or stained fixtures, dishes, or laundry) or (bad spray pattern, odor, low flow)</p> <p>4 Document on Attachment D filter inventory</p> <p>5 EPA recall list</p>														