



Environmental and Laboratory Services
 90 ½ West Blackwell St., Dover, New Jersey 07801
 (973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: June 12, 2017
 Address: Roxbury Township BOE
 1 Bryant Drive
 Succasunna, NJ 07876

Project: Roxbury Board of Education

Sample description: Drinking Water / 1st Draw / DWSC3217-1
 Sample location: LRS-SO-PE Office Mens
 Sampled by: Client
 Sample date: 06/06/17
 Time: 05:18
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	11.3 µg/L	15 µg/L	06/08/17	00:56	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3217-2
 Sample location: LRS-FB-HW by 107
 Sampled by: Client
 Sample date: 06/06/17
 Time: 05:32
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	11.0 µg/L	15 µg/L	06/08/17	01:02	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3217-3
 Sample location: RHS-CS-Concession Stand-01
 Sampled by: Client
 Sample date: 06/06/17
 Time: 05:58
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	567 µg/L	15 µg/L	06/08/17	17:28	100	200 µg/L

Sample description: Drinking Water / Flushed / DWSC3217-3A
 Sample location: RHS-CS-Concession Stand-01
 Sampled by: Client
 Sample date: 06/06/17
 Time: 06:09
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	5 µg/L	06/08/17	17:33	1	2.00 µg/L

$\mu\text{g/L}$ = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan Van Veen
Susan VanVeen, Lab Manager
NJ Laboratory Certification ID # 14013

6/13/17
Date

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Roxbury Board of Ed report to: Agra Environmental Service
 Address: 42 N. Hillside Ave 90 1/2 West Blackwell Street
Succasunna, NJ 07876 Dover, NJ 07801
 County/Municipality: MORRIS / Roxbury Phone: (973) 989-0010
 Phone: 973 584 1136 Fax: (973) 989-0156
 Work: _____

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake
 Project: _____ PWSID# NJ _____ for laboratory use _____

Field ID	Lab ID	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED
1	LRS-50-PE office men's 1st class	6/6/17	5:18						11.3 ug/L 6/8/17 0050 DM
2	LRS-50-PE office men (Flush)	6/6/17	5:27						140 ug/L 6/8/17 0103 DM
3	LRS-FB Hwy 107 (1st class)	6/6/17	5:32						567 ug/L 6/8/17 1728 DM
4	LRS-FB Hwy 107 (Flush)	6/6/17	5:44						42 ug/L 6/8/17 1733 DM
5	RHS CS consensus stand off (1st class)	6/6/17	5:58						
6	RHS CS consensus stand off (Flush)	6/6/17	6:07						

Sampled By (name/company): J-Stoia / Roxbury Bd of Ed State Forms Needed (circle one): Yes or No _____ indicate laboratory location where analysis requested was performed
 NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033
 Reporting Requirements (Check Box): NJ Reduced Other (Specify) _____ Cooler Temperature Upon Receipt at lab: _____

Scanned _____

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
<u>James</u>	6/6/17	8:45	<u>Julia MacDonald</u>	6/6/17	0849
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:

Date Faxed: _____ Invoice Number: _____
 Is sample known to be hazardous? (circle one) Yes or No

- # Asc./HCl Vials pH: _____
- # HCl Vials pH: _____
- # Na₂S₂O₃ _____
- # HNO₃ _____
- # H₂SO₄ _____
- # NaOH _____
- # unpreserved 6 (see note)
- # other _____
- # other _____