



Environmental and Laboratory Services

90 ½ West Blackwell St., Dover, New Jersey 07801

(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: June 27, 2017
Client: Roxbury Township BOE
Address: 1 Bryant Drive
Succasunna, NJ 07876

Project: Lincoln Roosevelt School

Sample description: Drinking Water / 1st Draw / DWSC3321-1
Sample location: LRS-FB-HW by 208
Sampled by: Client
Sample date: 06/15/17
Time: 05:40
Analyst: B. Moraga

| Parameter | Method | Sample Result | NJDEP Limit | Date Analyzed | Time Analyzed | Dilution Factor | Reporting Limit |
|-----------|---------|---------------|-------------|---------------|---------------|-----------------|-----------------|
| Lead | SM3113B | 13.7 µg/L | 15 µg/L | 06/16/17 | 17:36 | 1 | 2.00 µg/L |

Sample description: Drinking Water / Flushed / DWSC3321-2
Sample location: LRS-FB-HW by 208
Sampled by: Client
Sample date: 06/15/17
Time: 05:42
Analyst: B. Moraga

| Parameter | Method | Sample Result | NJDEP Limit | Date Analyzed | Time Analyzed | Dilution Factor | Reporting Limit |
|-----------|---------|---------------|-------------|---------------|---------------|-----------------|-----------------|
| Lead | SM3113B | 3.39 µg/L | 5 µg/L | 06/16/17 | 17:48 | 1 | 2.00 µg/L |

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen (For SV)
Susan VanVeen, Lab Manager
NJ Laboratory Certification ID # 14013

June 27, 2017
Date

