



Environmental and Laboratory Services
 90 1/2 West Blackwell St., Dover, New Jersey 07801
 (973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: September 15, 2016

Client: Roxbury Township BOE
 Address: 1 Bryant Drive
 Succasunna, NJ 07876

Project: Lincoln

Sample description: Drinking Water / 1st Draw / DWS3711-1
 Sample location: Field Blank
 Sampled by: D. Diaz / S. Warner
 Sample date: 09/02/16
 Sample time: 06:20
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	09/13/16	01:37	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3711-2
 Sample location: Faculty Room / FRS1
 Sampled by: D. Diaz / S. Warner
 Sample date: 09/02/16
 Sample time: 06:28
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	09/13/16	01:43	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3711-3
 Sample location: Cafeteria / KPS1
 Sampled by: D. Diaz / S. Warner
 Sample date: 09/02/16
 Sample time: 06:31
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	2.75 ug/L	15 ug/L	09/13/16	01:49	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3711-4
 Sample location: J Hall / WF1
 Sampled by: D. Diaz / S. Warner
 Sample date: 09/02/16
 Sample time: 06:25
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	10.9 ug/L	15 ug/L	09/13/16	01:55	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3711-5
 Sample location: H Hall / WF2
 Sampled by: D. Diaz / S. Warner
 Sample date: 09/02/16
 Sample time: 06:27
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	09/13/16	02:07	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3711-6
 Sample location: L Hall / WF3
 Sampled by: D. Diaz / S. Warner
 Sample date: 09/02/16
 Sample time: 06:21
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	2.49 ug/L	15 ug/L	09/13/16	02:20	2 ug/L

Sample description: Drinking Water / 1st Draw / DWS3711-7
 Sample location: N Hall / WF4
 Sampled by: D. Diaz / S. Warner
 Sample date: 09/02/16
 Sample time: 06:23
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	12.7 ug/L	15 ug/L	09/13/16	02:44	2 ug/L

ug/L= micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Lawrence Young (For SV)
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

September 29, 2016
 Date

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST



Customer Name: Roxbury BOE: Lincoln School	report to:	Agra Environmental Services
Address: 34 N. Hillside Ave	John Eschmann	90½ West Blackwell Street
Succasunna, NJ 07876	Roxbury BOE	Dover, NJ 07801
County/Municipality:	1 Bryant Dr.	Phone: (973) 989-0010
Phone: John: 973-607-9104	Succasunna, NJ 07876	Fax: (973) 989-0156
Work:	(973) 584-1136	

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project: Lincoln School	Collection	PWSID# None	for laboratory use only	Field Analysis
-------------------------	------------	-------------	-------------------------	----------------

Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED			
DWS 3711												
FIELD BLANK	-1	21-Sep	0620	X		D	1	HNO3	1st Draw Pb < 2 µg/L	9/13/16	0137	SM
FACULTY ROOM/FRS1	-2	21-Sep	0628	X		D	1	HNO3	1st Draw Pb < 2 µg/L		0143	
CAFETERIA/KPS1	-3	21-Sep	0631	X		D	1	HNO3	1st Draw Pb 2.75 µg/L		0149	
J HALL/WF1	-4	21-Sep	0625	X		D	1	HNO3	1st Draw Pb 10.9 µg/L		0155	
H HALL/WF2	-5	21-Sep	0627	X		D	1	HNO3	1st Draw Pb < 2 µg/L		0207	
L HALL/WF3	-6	21-Sep	0621	X		D	1	HNO3	1st Draw Pb 2.49 µg/L		0220	
N HALL/WF4	-7	21-Sep	0623	X		D	1	HNO3	1st Draw Pb 12.7 µg/L		0244	

Sampled By (name/company): D. Diaz/S. Warner	State Forms Needed (circle one): Yes or No	indicate laboratory location where analysis requested was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013	
	NJDEP Laboratory Certification (Marlboro, NJ) #13033	

Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:
-------------------------------------	----------	------------	-----------------	---

Sample Custody Exchanges (Please use full legal signature)						Scanned _____	
Relinquished By: <i>Daniela Diaz</i>	Date: 9/1/16	Time: 0732	Received By: <i>Stephano W...</i>	Date: 9/2/16	Time: 0733	year 2016	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No	